



Certificate of Compliance

Certificate: 80021568

Master Contract: 300413

Project: 80099726

Date Issued: 2021-10-07

Issued To: Jiangsu Ganghong Electric Wire and Power Cable Co., Ltd
Jiangshu Huangtang Town Danyang
Zhenjiang, Jiangsu, 212364
China

Attention: li jie

The products listed below are eligible to bear the CSA Mark shown



Issued by: Kim Nguyen
Kim Nguyen, P. Eng.

PRODUCTS

CLASS 5722 02 CABLE Power – Commercial and Industrial

Shielded power cables, single conductor construction, TRXLPE insulation (100%, 133% and 173%), PVC jacket, rated 5-46kV, 90C, low temperature -40C, FT1, FT4-ST1, SR.

APPLICABLE REQUIREMENTS

CSA C68.10 - Shielded power cable for commercial and industrial applications, 5-46KV



Supplement to Certificate of Compliance

Certificate: 80021568

Master Contract: 300413

*The products listed, including the latest revision described below,
are eligible to be marked in accordance with the referenced Certificate.*

Product Certification History

Project	Date	Description
80099726	2021-10-07	Update report 80021568 to requirements of CSA Certification Notice No. 254, standard C68.10-20.
80021568	2019-11-01	Original certification of shielded power cable, single conductor construction with CS Cat No YPJ-35, TRXLPE insulation HFDC-4202EC, IS Cat No YPB-35 and black PVC jacket Cat No. WJCK507, rated 5-46 kV, 90C, -40C, SR, FT1, FT4-ST1