



Certificate of Compliance

Certificate: 80044486

Master Contract: 300413

Project: 80044486

Date Issued: 2020-11-10

Issued To: Jiangsu Ganghong Electric Wire and Power Cable Co., Ltd
Jiangsu Huangtang Town
Danyang, Jiangsu, 212364
China

Attention: li jie

The products listed below are eligible to bear the CSA Mark shown

Issued by: *Simon Liang*
Simon Liang



PRODUCTS

CLASS - C572111 - Cable-TC-Control

CLASS - C572101 - CABLE Control

Type CIC, multi-conductor round construction rated 90°C Dry and Wet, 600V, FT1, FT4, -25°C, SR, TC, DIRECT BURIAL, with XLPE insulation and CSPE jacket, stranded Copper, size 14 to 4/0 AWG.

APPLICABLE REQUIREMENTS

CSA C22.2 No. 230 - Tray cables

CSA C22.2 No. 239 - Control and instrumentation cables



Supplement to Certificate of Compliance

Certificate: 80044486

Master Contract: 300413

*The products listed, including the latest revision described below,
are eligible to be marked in accordance with the referenced Certificate.*

Product Certification History

Project	Date	Description
80044486	2020-11-10	CIC, multiple-conductor round construction rated 90C dry/wet (-25C), 600V, FT1, FT4, SR, TC, stranded Copper conductor, 03 or more circuits. Size range: 14 AWG – 4/0 AWG.