



Certificate of Compliance

Certificate: 80128177

Master Contract: 300413

Project: 80128177

Date Issued: 2022-05-30

Issued To: Jiangsu Ganghong Electric Wire and Power Cable Co., Ltd
Jiangsu Huangtang Town Danyang
Zhenjiang, Jiangsu, 212364
China

Attention: Li Jie

The products listed below are eligible to bear the CSA Mark shown



Issued by: *Wilson Wang*
Wilson Wang

PRODUCTS

CLASS - C585101 - WIRES Appliance

Part A: Appliance Wiring Material, single conductor construction with PVC insulation, Class I, Group A, B or A/B, rated at 80C/90C/105C, 300V/600V/1000V, FT1, FT2, in sizes 40AWG to 2000kcmil.

Part B: Appliance Wiring Material, single or multi-conductor round cable construction with PVC insulation and PVC jacket, Class II or I/II, Group A, B or A/B, rated at 80C/90C/105C, 300V/600V/1000V, FT1, FT2, in sizes 40AWG to 2000kcmil, with optional shielding.

APPLICABLE REQUIREMENTS

CSA Standard C22.2 No. 210 - Appliance Wiring Material Products




Certificate: 80128177
Project: 80128177

Master Contract: 300413
Date Issued: 2022-05-30

Notes:

Products certified under Class C585101 have been certified under CSA's ISO/IEC 17065 accreditation with the Standards Council of Canada (SCC). www.scc.ca





Supplement to Certificate of Compliance

Certificate: 80128177

Master Contract: 300413

*The products listed, including the latest revision described below,
are eligible to be marked in accordance with the referenced Certificate.*

Product Certification History

Project	Date	Description
80128177	2022-05-30	Original certification of single or multi-round AWM, I, II or I/II, A, B or A/B, with PVC insulation and PVC jacket (as applicable), rated at 80/90/105C, 300/600/1000V, FT1, FT2, in sizes 40AWG to 2000kcmil. CSA Std. C22.2 No. 210-15.