



Certificate of Compliance

Certificate: 80126089

Master Contract: 300413

Project: 80126089

Date Issued: 2022-05-13

Issued To: Jiangsu Ganghong Electric Wire and Power Cable Co., Ltd
Jiangshu Huangtang Town Danyang
Zhenjiang, Jiangsu, 212364
China

Attention: Li Jie

The products listed below are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US' for Canada and US or with adjacent indicator 'US' for US only or without either indicator for Canada only.



Issued by: Wilson Wang
Wilson Wang

PRODUCTS

CLASS - C583101 - WIRES Flexible Cord

CLASS - C583181 - WIRES Flexible Cord - Certified to US Standards

Types SJ, SJO, SJOO, SJOW, SJOOW, 300V, rated 60C, 75C and 90C, FT1, FT2, VW-1 and optional FT4.

Types S, SO, SOO, SOW, SOOW, 600V, rated 60C, 75C and 90C, FT1, FT2, VW-1 and optional FT4.

APPLICABLE REQUIREMENTS

CSA C22.2 No. 49 - Flexible Cords and Cables

UL 62 - Flexible Cords and Cables




Certificate: 80126089
Project: 80126089

Master Contract: 300413
Date Issued: 2022-05-13

Notes:

Products certified under Class C583101, C583181 have been certified under CSA's ISO/IEC 17065 accreditation with the Standards Council of Canada (SCC). www.scc.ca





Supplement to Certificate of Compliance

Certificate: 80126089

Master Contract: 300413

*The products listed, including the latest revision described below,
are eligible to be marked in accordance with the referenced Certificate.*

Product Certification History

Project	Date	Description
80126089	2022-05-13	Certification of flexible cords, types SJ, SJO, SJOO, SJOW, SJOOW, S, SO, SOO, SOW and SOOW with EP insulation "GH-CJR01B" and CPE jacket "GH-CHR01B", rated FT1, FT2, VW-1 and optional FT4. CSA Std. C22.2 No. 49-18 and UL62 20 th Ed.