

CERTIFICATE OF COMPLIANCE

Certificate Number 20180917-E498728
Report Reference E498728-20180913
Issue Date 2018-SEPTEMBER-17

Issued to: JIANGSU GANGHONG ELECTRIC WIRE & POWER
CABLE CO LTD
JIANGSHU, HUANGTANG TOWN
DANYANG, JIANGSU 212364 CHINA

**This is to certify that
representative samples of** THERMOSET-INSULATED WIRE
Type RW90, rated 600 V and 2000 V.

Have been investigated by UL in accordance with the
Standard(s) indicated on this Certificate.

Standard(s) for Safety: UL 44, Thermoset-Insulated Wires and Cables
CSA C22.2 No. 38, Thermoset-Insulated Wires and Cables

Additional Information: See the UL Online Certifications Directory at
www.ul.com/database for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's
Certification and Follow-Up Service.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please
contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

